



SAMPLE PLOT PLAN

FOR DECK



Requirements for Residential Deck Permits



Village Of Little Chute
Inspections Department
06/02

Requirements for Residential Deck Permits


The purpose of this pamphlet is to help expedite the approval of your deck permit application.

Permits Required


Before any work is started on the construction of a deck you are required to complete an application for permit. You should have information as to the builder of the deck if you are contracting this out. This would include the company name, address and phone number. A contact name is also helpful in the event that any questions may arise.

Along with the application for permit, a plot plan showing the exact location of the proposed deck is required. A plot plan is a scaled drawing that details the location of the structures on your lot and shows their relation to the lot lines. In this drawing you will include your home, garage and any other structures. The size for this drawing shall be no less than 8 x 10 inches in size. An example of a plot plan has been included on the back of this pamphlet.

Along with the plot plan you will need to have a plan for the deck. This plan should detail the location and size of the support



The Home Depot #1926, 2201 S KENSINGTON AVE, APPLETON, WI 54915
Mon Sep 24 10:23:05 2001
File saved as: f:\dn\decks\924091DD.DEK
Deck Dimensions for Deck 1



Joist Spacing = 16 in. o.c.
Railpost Spacing = 96 in. o.c., Baluster Spacing = 3 in., Toe Spacing = 3 in., Railing Height =

posts (or foundation), size and location of any beams and the size and spacing of the floor joists. Any stairs used must also be detailed. Minimum size for this plan is also 8x10 inches. Your lumber company will be able to provide you with this information if you are unsure of how to design a deck.

Construction Requirements

- 1.) Lot Area Coverage. No deck may be located in any portion of a required front or side yard. The deck may not occupy more than 30% of the required rear yard. Total lot coverage by all structures shall not exceed 35% of the total lot area. This will include all structures- swimming pools, play structures, detached garage, and decks.
- 2.) A deck which is attached to the principal building shall comply with the yard requirements and construction standards of the principal building. The minimum required side yard clearance is 7 feet. The minimum rear yard clearance is 20 feet and front yard is 25 feet.
- 3.) Foundations & Footings. All decks shall be provided with a foundation below the frost line. This would be 48 inches in depth. Posts shall be set on a concrete

footing adequate in size to support the loads of the deck.

- 4.) Construction Standards. Wood frame decks must conform to the following standards. Joists shall have a maximum spacing of 16 inches on center. The floor system shall be designed to meet a load of 40 pounds per square foot, plus 10 pounds per square foot dead load. All lumber within 8 inches of grade shall be treated or of a rot resistant species. Any wood surfaces exposed to the weather shall be treated or provided with a weathering protectant such as stain or a water-proofing agent.
- 5.) Guard Rails. All decks with a surface height of more than 24 above grade shall be provided with guard rails. The guardrail shall have a minimum height of 36 inches above the deck surface. The guardrail shall have intermediate members or balusters spaced so that they shall not allow the passage of a 4 inch sphere between members. This requirement also pertains to the space between the bottom member of the guardrail and the deck surface. The guardrail will be of adequate strength to resist a horizontal load of 200 pounds.

- 6.) Stairs. All stairs leading to a deck shall measure at least 36 inches in width. The maximum height for a stair rise is 8 inches, and all risers shall be uniform in height. The minimum tread width shall not be less than 9 inches. All stairs with more than 3 risers must be provided with a handrail. This handrail shall be located between 30 & 38 inches above the nose of the tread surfaces, and be uniform in height over the run of the stairs. The guard rail must be continuous over the entire run of the stairs, and the gripping surface of the rail will have a maximum cross section of 2-7/8 inches. Intermediate members or balusters shall be provided and spaced so that they shall not allow the passage of a 4 inch sphere between the members. The handrail will be of adequate strength to resist a horizontal load of 200 pounds.